


PULSE GENERATOR
PERFORMANCE CHECK

Model: *AMP-N-1-B-N*
S.N.: *10869*
Date: *MAR 22 2004*



- a) Output signal amplitude: *0 to 10V (to 50Ω)*
- b) Pulse width: *0.4 to 4.0 ns*
- ① c) Rise time: *≤ 200 ps*
- ② d) Fall time: *≤ 200 ps*
- ③ e) PRF: *0 to 1.0 MHz.*
- f) Jitter, stability: *OK*
- g) Prime power: *100 VOLTS TO 240V*
50 - 60 Hz.

40 dB ATTN. : 10V/DIV

① *1 NS / DIV*

② *200ps / DIV, RISE TIME*

③ *200ps / DIV, FALL TIME*

PRF = 100 KHz for
1, 2 + 3.

100 VOLTS TO 240V
50 - 60 Hz.



AVTECH ELECTROSYSTEMS LTD.

NANOSECOND WAVEFORM ELECTRONICS
SINCE 1975

P.O. BOX 265
OGDENSBURG, NY
U.S.A. 13669-0265
TEL: (315) 472-5270
FAX: (613) 226-2802

TEL: 1-800-265-6681
FAX: 1-800-561-1970

e-mail: info@avtechpulse.com
<http://www.avtechpulse.com/>

BOX 5120, LCD MERIVALE
OTTAWA, ONTARIO
CANADA K2C 3H4
TEL: (613) 226-5772
FAX: (613) 226-2802

"-B" Functional Test & Calibration Certificate

Date of test:	March 19, 2004				Tester:	MJC
Programmed model name:	AVP-AV-1-B-N					
Programmed serial number:	10869					
Firmware revision:	2.57					
Internal trigger checked at:	1 Hz	1 kHz	10 kHz	100 kHz	1 MHz	
Actual measured output ¹ :	0.999 Hz	0.998 kHz	9.981 kHz	100.3 kHz	1.009 MHz	
External trigger checked:	Yes			Gate checked:	Yes	
Manual trigger checked:	Yes					
Pulse compression checked:	N/A		Low Amplitude PW Distortion Nulled:		N/A	
Pulse width checked at:	0.4 ns	1 ns	2.5 ns	4 ns	100 kHz, -10V to 50Ω	
Actual measured output ² :	0.38 ns	1.05 ns	2.6 ns	4.0 ns		
PWin = PWout mode checked:	N/A		DC mode checked:		N/A	
Duty Cycle Limit:	N/A					
Delay nulled:	Yes					
Delay checked at:	100 ns	1 us	10 us	100 us	100 Hz, -10V to 50Ω	
Actual measured output ¹ :	100.1 ns	1.001 us	10.02 us	100.1 us		
Double pulse checked:	N/A					
Invert mode checked:	N/A					
ECL/TTL modes checked:	N/A					
Zout switch checked:	N/A					
Amplitude checked at:	-2V	-5V	-8V	-10V	100 kHz, 4 ns PW to 50Ω	
Actual measured output ² :	-2.1V	-5.2V	-8.0V	-10.2V		
Amplitude polarity:	-					
Zout calibration:	N/A					
Electronic amplitude control:	N/A					
External amplify mode:	N/A					
Bleeder resistors adequate:	N/A					
Burst mode:	N/A					
Monitor V/I Ratio:	N/A		Monitor offset nulled:			
LCD Monitor calibrated:	N/A					
Offset checked at:	N/A					
Actual measured output ² :	N/A					
Offset nulled (output on):	N/A		Amplitude-dependent offset nulled:			
Offset nulled (output off):	N/A					
RS-232 checked:	Yes					
LCD pull-ups installed:	N/A					
PCB 108G/H resistor updates:	Yes					
PN trigger pull-downs installed:	Yes					
Sync pulse width checked:	100 ns					
Circuit Boards:	PS:	158E	Main:	108H		
Overload Trigger Resistance:	Trips at:	N/A	Installed:	N/A		
DC fuses:	Main:	0.8A	Overload:	0.8A (spare)		
AC Current:	Quiescent:	0.18A @ 115V 0.15A @ 230V	Max. Load:	0.21A @ 115V 0.16A @ 230V		
AC fuse:	0.5A					
1.5 kV RMS, 5 second Hypot Test:	OK					
25A RMS Ground Continuity Test:	OK					
Fan operational:	Yes					
Photographed:	Yes					

¹ Checked with: Fluke PM6681 Counter (S/N 9446 066 81016), referenced to Datum ExacTime 9390-6000 (S/N 4461) GPS Frequency Reference

² Checked with: Tektronix TDS3052 digital oscilloscope (S/N B014783) for PW ≥ 5 ns, Tektronix 7704A/7S11/7T11/S4 sampling oscilloscope (Cal. Label 112506) for PW < 5 ns.