

PULSE GENERATOR  
PERFORMANCE CHECK


Model: *AV-1011-B*  
S.N.: *9909*  
Date: *JUN 27 2001*

- a) Output signal amplitude:  
*0 to  $\pm 100V$  ( $R_L \geq 50\Omega$ )*
- b) Pulse width:  
*100 ns to 1  $\mu$ s*
- c) Rise time:  
*(10% MAX DUTY CYCLE)  
 $\leq 10$  ns*
- d) Fall time:  
 *$\leq 10$  ns*
- e) PRF:  
*0 to 1 MHz  
(10% MAX DUTY CYCLE)*
- f) Jitter, stability:  
*OK*
- g) Prime power:  
*120/240V  
50 to 60 Hz*

*[Signature]*


Ⓟ

9909  
POS OUT  
 $R_{out} = 50\Omega$   
 $R_{comp} = 50\Omega$   
PBF = 1 MHz  
(NARROW PULSES)



(B)

9909  
POS OUT  
 $R_{OUT} = 2\ \Omega$   
 $R_{LOAD} = 50\ \Omega$   
 $PRF \approx 100\text{ kHz}$



©

9909


NEG OUT

$R_{out} = 2\Omega$

$R_{load} = 50\Omega$

$P_{RF} = 100\text{W}$

(WIDE PULSE)





P.O. BOX 265  
 OGDENSBURG, NY  
 U.S.A. 13669-0265  
 TEL: (315) 472-5270  
 FAX: (613) 226-2802

TEL: 1-800-265-6681  
 FAX: 1-800-561-1970

e-mail: info@avtechpulse.com  
 http://www.avtechpulse.com

P.O. BOX 5120 STN. F  
 OTTAWA, ONTARIO  
 CANADA K2C 3H4  
 TEL: (613) 226-5772  
 FAX: (613) 226-2802

## "-B" Functional Test & Calibration Certificate

Date of test:	July 12, 2001				Tester:	MJC
Programmed model name:	AV-1011-B					
Programmed serial number:	9909					
Firmware revision:	2.26					
Internal trigger checked at:	1 Hz	100 Hz	1 kHz	100 kHz	1 MHz	
Actual measured output <sup>1</sup> :	0.997 Hz	99.6 Hz	0.997 kHz	100.3 kHz	1.008 MHz	
External trigger checked:	yes			Gate checked:	yes	
Manual trigger checked:	yes					
Pulse compression checked:	yes	Low Amplitude PW Distortion Nulled:			N/A	
Pulse width checked at:	100 ns	1 us	10 us	1 ms	100 Hz, +100V	
Actual measured output <sup>2</sup> :	98.9 ns	1.003 us	9.99 us	1.003 ms	to 50 Ohms	
PWin = PWout mode checked:	yes			DC mode checked:	N/A	
Duty Cycle Limit:	10%					
Delay nulled:	yes					
Delay checked at:	100 ns	1 us	10 us	1 ms	100 Hz, +100V	
Actual measured output <sup>1</sup> :	99.6 ns	0.997 us	9.992 us	1.003 ms	to 50 Ohms	
Double pulse checked:	yes					
Invert mode checked:	N/A					
ECL/TTL modes checked:	N/A					
Zout switch checked:	yes					
Amplitude checked at:	-10V	+20V	-50V	+100V	100 Hz, 10 us	
Actual measured output <sup>2</sup> :	-10.04V	+20.0V	-50.2V	+100.0V	to 50 Ohms	
Amplitude polarity:	+/-					
Zout calibration:	N/A					
Electronic amplitude control:	OK					
External amplify mode:	N/A					
Ultravolt flux removed:	OK					
Monitor V/I Ratio:	N/A			Monitor offset nulled:		
LCD Monitor calibrated:	N/A			Monitor offset nulled:		
Offset checked at:	N/A					
Actual measured output <sup>2</sup> :	N/A					
Offset nulled (output on):	N/A			Amplitude-dependent offset nulled:		
Offset nulled (output off):	N/A					
RS-232 checked:	yes					
Sync pulse width checked:	50 ns					
Circuit Boards:	PS:	93	Main:	108B		
Overload Trigger Resistance:	Trips at:	N/A	Installed:	3.9K		
DC fuses:	Positive:	2A	Negative:	N/A		
AC Current at 115 VAC:	Quiescent:	0.44	Max. Load:	0.82A		
AC fuse:	1A					
Photographed:	no					

<sup>1</sup> Checked with: Fluke PM6681 Counter, referenced to Datum ExacTime 9390-6000 GPS Frequency Reference

<sup>2</sup> Checked with: Tektronix TDS3052 digital oscilloscope for PW ≥ 5 ns,  
 Tektronix 7704A/7S11/7T11/S4 sampling oscilloscope system for PW < 5 ns.