

AVTECH ELECTROSYSTEMS LTD.

NANOSECOND WAVEFORM ELECTRONICS

P.O. BOX 265
 OGDENSBURG, NY
 U.S.A. 13669-0265
 TEL: (315) 472-5270
 FAX: (613) 226-2802

BOX 5120 STN. F OTTAWA, ONTARIO CANADA K2C 3H4 TEL: (613) 226-5772 FAX: (613) 226-2802

INSTRUCTIONS


MODEL AVH-MPT-TP1 IMPULSE GENERATOR

S.N.:

WARRANTY

Avtech Electrosystems Ltd. warrants products of its manufacture to be free from defects in material and workmanship under conditions of normal use. If, within one year after delivery to the original owner, and after prepaid return by the original owner, this Avtech product is found to be defective, Avtech shall at its option repair or replace said defective item. This warranty does not apply to units which have been dissembled, modified or subjected to conditions exceeding the applicable specifications or ratings. This warranty is the extent of the obligation or liability assumed by Avtech with respect to this product and no other warranty or guarantee is either expressed or implied.

IMPULSE GENERATOR TEST ARRANGEMENT



Notes:

- The bandwidth capability of components and instruments used to display the impulse generator output signal (attenuators, cables, connectors, etc.) should exceed ten gigahertz.
- 2) The use of 50 db attenuation will insure a peak input signal to the sampling scope of less than one volt.
- 3) In general, the pulse generator trigger delay control should be set in the 100 ns range. Other settings should be as shown in the above diagram. The impulse generator output is delayed with respect to the trigger input signal by ≤ 2 ns (typically).
- 4) The impulse generator can withstand an infinite VSWR on the output port.

06.01.92

reader.

- 1) The Cleanerd's Equation is a component, and instrumenter used to alloptate the resource generator culture transit of behaviores tibles. Consectors, and eshable entreed the constitution.
- 2) The real of Sirk attemption will their a near there.
 3) The real of cathemption of the Star of vali.
- 3. In grown 2, the prise generator crower delay control whould be set in the 200 of range. Other settings around in restance to the above dragram. The inputts merce of mutput is delayed with respect to the triguer fact sized by the flagtestyd.
- First mentile the second net of this beach an infinite VSWN on the school south.